

106.2.8.1 Non-complying work. Whenever any work is being done contrary to provisions of this code, the fire code official is hereby authorized to order such work stopped. Such work should immediately stop until authorized by the fire code official to proceed.

106.2.9 Standby personnel. When, in the opinion of the fire code official, it is essential for public safety in a tent, canopy or membrane structure used as a place of assembly or any other use where people congregate, or any building, premises or property where people congregate, because of the number of persons, or the nature of the performance, exhibition, display, contest or activity, or when potentially hazardous conditions exist, or an occupant load varies due to large crowd movement from one building to another building or one area of a building to another area of the building, or there is a reduction in a life safety feature, or there is an impairment to a fire protection feature, the owner, agency or lessee shall employ and compensate through approved Department of Safety channels at a rate established by the Manager of Safety one or more firefighters of the City and County of Denver, as required by the fire code official. Such firefighter(s) shall be subject to the fire code official's orders at all times when so employed and shall be in uniform and remain on duty during the times such places are open to the public or when such activity is being conducted or, in the case of residential occupancies, whenever occupied.

106.2.9.1 Owner's responsibility. The owner, agent, or lessee shall employ standby fire personnel in an adequate number determined by the fire code official based on the potential hazard or reduction in a fire protection system or other life safety feature as described in Section 106.2.9, as required and approved, to be on duty. Such standby fire personnel or fire watch personnel shall be subject to the fire code official's orders at all times and shall be identifiable and remain actively on duty during the times such places are open to the public, when such activity is being conducted, or in residential buildings, whenever occupied.

106.2.10 Records. The Fire Prevention and Investigation Division shall retain for not less than seven years a record of each inspection made showing the findings and disposition of each inspection made.

106.2.11 Townhouses and condominiums. Portable fire extinguishers shall be mounted on the exterior at each level stairway(s) or one (2A 10BC) within each residential unit. When mounted on the exterior, the property management/homeowner's association (HOA) shall be responsible for the care, maintenance and recharging, and use of the fire extinguisher, including inspection. The homeowner shall submit a report to the property management (HOA) on an annual basis. Portable fire extinguishers shall be inspected and maintained in accordance with NFPA 10. The smoke detector(s) within the residential units shall be tested and maintained in accordance with NFPA 72. The homeowner shall submit a report to the property management/HOA on an annual basis of each test and battery replacement. The property management/HOA shall maintain a log of the inspection/test reports submitted to that office and Denver Fire Department Inspection personnel will review that log prior to conducting the inspection. If this information is not available, an inspection shall be made to determine that this equipment is in compliance with this code.

Add Section 106.5 as follows:

106.5 Fees. The Manager of Safety is authorized to adopt an inspection fee schedule necessary to cover administrative costs of inspections and record-keeping under this code.

**SECTION 107
MAINTENANCE**

Add Sections 107.7 and 107.8 as follows:

107.7 Standby Personnel. The fire code official shall have the authority to require standby fire personnel or an approved fire watch when potentially hazardous conditions or a reduction in a fire protection system or other life safety feature exist due to the type of performance, display, exhibit, occupancy, contest, or activity; an impairment to a fire protection or other life safety system; or the number of persons present.

Delete Section 905.3.4.1 Hose and cabinet.

Delete Section 905.5.3 Class II system 1-inch hose.

SECTION 906 PORTABLE FIRE EXTINGUISHERS

Amend Section 906.1 by deleting Exception to Item #1.

Add Section 906.2.1 as follows:

906.2.1 Verification of service collars. Every portable fire extinguisher, regardless of type, shall have a verification of service collar in accordance with NFPA 10 Section 7.3.3.2. Only collars available at the Denver Fire Department are allowed. Collars shall not be cut.

Add Section 906.3.1 as follows:

906.3.1 Distribution in R-1 and R-2 occupancies. In R-1 and R-2 occupancies with entrances to dwelling units opening to outside, the maximum travel distance to a fire extinguisher from any point in the occupancy shall be placed no more than 75 feet. Alternatively, fire extinguishers may be placed inside each dwelling unit when approved by the Fire Department.

SECTION 907 FIRE ALARM AND DETECTION SYSTEMS

Replace Section 907.1 as follows:

907.1 General requirements. This section covers the application, installation, performance and maintenance of fire alarm systems and their components. Fire alarm systems, automatic fire detectors, emergency voice/alarm communication systems and notification devices shall be designed, installed and maintained in accordance with NFPA 72. Installation system wiring shall also be in accordance with NFPA 70 (*National Electrical Code*) and NFPA 72 (*National Fire Alarm Code*).

907.1.1 Construction documents. Construction documents for fire alarm systems shall be submitted for permit application as a deferred submittal per IBCA Section 154. Document review and approval is required prior to issuance of a permit for system installation. Two sets of scaled, engineered installation shop drawings shall be submitted. Documents shall be of sufficient clarity and detail to fully describe the scope of work. Handwritten notes and comments on reproduced drawings are not acceptable. Documents shall include, but are not limited to, the following as applicable:

1. Completed permit application with exact address, location of work, name and address of responsible design agency and original seal and signature of the design professional.
2. Building occupancy classification and occupant load for each occupancy classification.
3. Manufacturers' specification sheets for all equipment and devices.
4. Code reference used as a basis of design, including any administrative modifications or Board of Appeals decisions.
5. Identification of system as code-required, non-required code-compliant or user-defined.
6. Voice message content and language(s) for voice evacuation systems.
7. Complete sequence of operation including:
 - a. Elevator recall